



TITLE		NOTE:		DESCRIPTION:		DATE		VERSION		NOTES		TANK SPECIFICATION :			
PW.4x2x1.5.TIF.AB		Purewater sectional tanks must be fully supported on a flat, level & continuous foundation which provides structural support to the tank when full to maximum capacity. It is essential that the installer and/or user refers to the conditions of the installation document prior to the installation of the tank. Under no circumstances should any part of the tank structure be used to provide support to pipework and/or any ancillary items.		PW.4x2x1.5.TIF Sectional cold water storage tank c/w raised float valve housing to provide an AB Air gap		26/01/2023		A		FIRST ISSUE		INTERNAL DIMENSIONS 4150 x 2150 x 1650mm			
DRAWN BY C.MORRIS		DATE 31/01/2023										EXTERNAL DIMENSIONS 4224 x 2224 x 2210mm			
												NOM. CAPACITY 14,722 Litres			
												INSULATION THICKNESS 38mm			
												MATERIAL Hot press moulded GRP			
CUSTOMER CUSTOMER		ALL DIMENSIONS+/- 5mm UNLESS OTHERWISE STATED		A4		ALL DIMENSIONS IN MM - DO NOT SCALE						SCALE:1:50			
												SHEET 1 OF 1			