


A		B		C		D	
6		5		4		3	
2		1					
A		B		C		D	
6		5		4		3	
2		1					

TITLE		NOTE:		DESCRIPTION:		DATE		VERSION		NOTES		TANK SPECIFICATION :					
PW.2x1x1.TIF.AG		Purewater sectional tanks must be fully supported on a flat, level & continuous foundation which provides structural support to the tank when full to maximum capacity. It is essential that the installer and/or user refers to the conditions of the installation document prior to the installation of the tank. Under no circumstances should any part of the tank structure be used to provide support to pipework and/or any ancillary items.		PW.2x1x1.TIF Sectional cold water storage tank c/w access manway to provide an AG Air gap		23/01/2023		A		FIRST ISSUE		INTERNAL DIMENSIONS				2150 x 1150 x 1150mm	
DRAWN BY C.MORRIS		DATE 30/01/2023										EXTERNAL DIMENSIONS				2224 x 1224 x 1351mm	
CUSTOMER												NOM. CAPACITY				2843 Litres	
												INSULATION THICKNESS				38mm	
												MATERIAL				Hot press moulded GRP	
														</			