


TITLE		NOTE: All Purewater tanks must be fully supported on a flat,level & continuous foundation providing structural support to the tank when full to maximum operating capacity.It is essential that the user refers to the conditions of installation document prior to the installation of the tank.Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.		DESCRIPTION:	PW12000-2 piece cold water storage tank suitable for AG/AF Air gap	DATE 07/01/2022	VERSION A	NOTES FIRST ISSUE	TANK SPECIFICATION :			
PW338-UN									INTERNAL DIMENSIONS	610 x 610 x 910mm		
									EXTERNAL DIMENSIONS	805 x 805 x 917mm		
									NOM. CAPACITY	338 Litres		
									DRY WEIGHT	25 KG		
									INSULATION THICKNESS	NONE		
DRAWN BY	C.MORRIS	DATE	07/01/2022						WRAS CERT. NUMBER	131006	SCALE:1:20	
CUSTOMER	CUSTOMER								MATERIAL	GRP		
		ALL DIMENSIONS+/- 5mm UNLESS OTHERWISE STATED		A4	ALL DIMENSIONS IN MM - DO NOT SCALE							