



|           |            |  |            |  |  |                      |  |              |             |                      |                      |             |  |
|-----------|------------|--|------------|--|--|----------------------|--|--------------|-------------|----------------------|----------------------|-------------|--|
| TITLE     |            | NOTE   |            | DESCRIPTION:   |  | DATE                 |  | VERSION      | NOTES       | TANK SPECIFICATION : |                      |             |  |
| PW5625-UN |            | All Purewater tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank. |            | PW5625-UN One piece cold water storage tank suitable for AG/AF Air gap |  | 11/01/2022           |  | A            | FIRST ISSUE |                      |                      |             |  |
| DRAWN BY  | J. Ellison | DATE   | 11/01/2022 | ALL DIMENSIONS +/- 5mm UNLESS OTHERWISE STATED                         |  | ALL DIMENSIONS IN MM |  | DO NOT SCALE |             | INTERNAL DIMENSIONS  | 2500 x 1500 x 1500mm | SCALE: 1:40 |  |
| CUSTOMER  |            |  |            |  |  |                      |  |              |             | EXTERNAL DIMENSIONS  | 2694 x 1694 x 1593mm |             |  |
|           |            |  |            |  |  |                      |  |              |             | NOM. CAPACITY        | 5625 Litres          |             |  |
|           |            |  |            |  |  |                      |  |              |             | DRY WEIGHT           | 300 KG               |             |  |
|           |            |  |            |  |  |                      |  |              |             | INSULATION THICKNESS | NONE                 |             |  |
|           |            |  |            |  |  |                      |  |              |             | WRAS CERT. NUMBER    | 131006               |             |  |
|           |            |  |            |  |  |                      |  |              |             | MATERIAL             | GRP                  |             |  |