





TITLE	
CUCOMP.7500-3000 c/w skid	
DRAWN BY	J. Ellison
DATE	04/03/2022
CUSTOMER	CUSTOMER

NOTE:	
All Purewater tanks must be fully supported on a flat level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.	
ALL DIMENSIONS +/- 5mm UNLESS OTHERWISE STATED	A4

DESCRIPTION:	
CUCOMP.7500-3000.AG Airgap Combination Unit c/w steel skid	
ALL DIMENSIONS IN MM - DO NOT SCALE	

DATE	VERSION	NOTES
04/03/2022	A	FIRST ISSUE

TANK SPECIFICATION :	
WET COMPARTMENT	1000 x 2000 x 1500mm
DRY COMPARTMENT	1500 x 2000 x 1500mm
EXTERNAL DIMENSIONS	2692 x 2192 x 1818mm
NOMINAL CAPACITY	3000 Litres
INSULATION THICKNESS	25mm
MATERIAL	GRP

purewater storage ltd	
SCALE:1:35	SHEET 2 OF 2