



TITLE
CUCOMP.8000-4000

DRAWN BY J. Ellison DATE 04/03/2022

CUSTOMER

NOTE:
All Purewater tanks must be fully supported on a flat level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.

ALL DIMENSIONS +/- 5mm
UNLESS OTHERWISE STATED

A4

DESCRIPTION:
CUCOMP.8000-4000.AG Airgap Combination Unit

ALL DIMENSIONS IN MM DO NOT SCALE

DATE	VERSION	NOTES
04/03/2022	A	FIRST ISSUE

TANK SPECIFICATION :		
WET COMPARTMENT	1000 x 2000 x 2000mm	
DRY COMPARTMENT	1000 x 2000 x 2000mm	
EXTERNAL DIMENSIONS	2192 x 2192 x 2118mm	
NOMINAL CAPACITY	4000 Litres	
INSULATION THICKNESS	25mm	
MATERIAL	GRP	



SCALE:1:40 SHEET 1 OF 2

