

Lakeside Primary Access Audit Oct 2018

SCHOOL BUILDINGS

1	Number of teaching spaces in main building	12	2	Number of teaching spaces which are accessible	10
3	Number of social spaces in main building	2	4	Number of social spaces that are accessible	2

Please answer the questions as follows: 1 = yes completely, 2 = almost, working towards compliance, 3 = partially, 4 = not yet considered.

	GENERAL	1	2	3	4	Comments
5	Are external pathways and routes logical and well signed	√				
6	Do you have emergency and evac procedures to alert all pupils	√				
7	Are internal routes logical and well signed		√			Fire exits clearly marked, nearest exit signs in all rooms.
8	Is appropriate furniture & equipment provided to meet individual needs	√				
9	Do furniture layouts allow for easy movement of pupils with disabilities		√			Staff to ensure room layout accommodates exit routes.
10	Are quiet/calming rooms available to pupils who need this facility	√				Rainbow room.
	GETTING INTO THE BUILDING					
11	Do you have reserved parking for disabled people near the main entrance		√			One designated space adjacent to main entrance.
12	Are there any barriers to prevent ease of movement	√				
13	Is level access provided at the main entrance	√				
	INTERNAL FACILITIES		Yes	No	N/a	Comments
14	Is it possible for a wheelchair user to get through the main entrance unaided?		√			Out ward opening door, handle at correct height, but no means to call for assistance. Door not mechanically assisted.
15	Does the entrance lobby accommodate wheelchair access		√			The lobby is secure, but laid out to accommodate wheel chairs
16	Do all internal doors allow a wheelchair user to negotiate the doors?			√		No, restricted access to Hope Room, Library and pupil toilets. Assistance to be reviewed in PEEP.

17	Do all corridors have a clear unobstructed width of 1.2m?		√			
18	Does the building have a wheelchair accessible toilet		√			Disabled toilet in mobile building with disabled access.
	VERTICAL MOVEMENT		Yes	No	N/a	Comments
20	Is the building more than one level			√		
	SENSORY IMPAIRMENT					
21	Are non-visual guides used to assist people using the building			√		
22	Could any of the décor be confusing or disorientating for pupils with disabilities			√		
23	Is a hearing induction loop available (fixed or portable)			√		
24	Does the fire alarm cater for those with hearing impairments			√		

	IMPROVEMENT WORKS	TIMESCALE
	Provide a bell to allow visitors to alert office	Within 1 month.
	A disabled toilet facility must form part of any schemes for internal alteration.	TBC.
	Increasing door opening width to pupil toilets should form part of any future toilet area alterations/refurbishments.	TBC.