



# PENETRATION & LINEAR GAP SEALS SCHEME SDP13

**Certificate number: IFCC 1669**

Certificate only valid if verified on website - [www.ifccertification.com](http://www.ifccertification.com)

This is a product certificate to certify that

*Pre-Formed Components Ltd trading as*

***PFC COROFIL***

Units 3 & 4  
King George Trading Estate  
Davis Road  
Surrey  
KT9 1TT  
Telephone no. +44 (0) 208 391 0533  
[www.pfc-corofil.com](http://www.pfc-corofil.com)

Which manufacture the following systems:

**CFSC PFC Corofil Fire Stop Compound**

have satisfied the requirements of the above scheme. This includes the testing of products to BSEN 1366-3: 2009 and BSEN 1363-1: 1999, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specifications to achieve up to 240 minutes Fire Resistance (Integrity) are given in the following report detailed below:

Test Report: BMT/FEI/F14015



First Issued: 5<sup>th</sup> October 2021

Valid to: 4<sup>th</sup> October 2026

Issue status: 1

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

**Ian Woodhouse**  
**Director of Certification**



175

---

IFC Certification Ltd  
20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.