CERTIFICATE OF COMPLIANCE

Certificate Number A-R15960

Report Reference R15960-19990426

Date 2021-June-23

Issued to: CARBOLINE (INDIA) PVT LTD

357 SIDCO INDUSTRIAL ESTATE

AMBATTUR

MADRAS Tamil Nadu 600098 IN

This is to certify that representative samples of

SPRAY-APPLIED FIRE-RESISTIVE MATERIALS

The cementitious mixture is marketed under the following

trade name:

Pyrocrete - Type 40, Type 40T

Have been investigated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety: See Addendum Page

Additional Information: See the UL Online Certifications Directory at

https://ig.ulprospector.com for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.





CERTIFICATE OF COMPLIANCE

Certificate Number A-R15960

Report Reference R15960-19990426

Date 2021-June-23

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Standard(s) for Safety:

Standard	Title
UL 263	Fire Tests of Building Construction and Materials
ULC S101-14-REV2	Standard Methods of Fire Endurance Tests of Building Constructions and Materials
UL 1709	Rapid Rise Fire Tests of Protection Materials for Structural Steel





